

**ADDENDUM NO. 1**  
**TO**  
**REQUEST FOR SEALED QUOTE, SPECIFICATIONS**  
**FOR**  
**TANK WASHOUT AND MISCELLANEOUS REPAIRS**  
**FOR**  
**THE COMMISSION OF PUBLIC WORKS**  
**SPARTANBURG WATER SYSTEM**  
**CITY OF SPARTANBURG, SOUTH CAROLINA**

---

Quote Due Date: January 10, 2019 at 2:00 PM, Eastern Time

---

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY INSERTING ITS NUMBER IN THE "BID" INCLUDED WITH THE BIDDING DOCUMENTS; FAILURE TO DO SO MAY SUBJECT BONA FIDE BIDDER TO DISQUALIFICATION. THIS ADDENDUM FORMS A PART OF THE PROJECT DOCUMENTS; IT MODIFIES THEM AS FOLLOWS:**

**SPECIFICATIONS**

**Section 33 01 10.56**  
**Paragraph 3.2 C.**  
**Page 4 of 5**

**Modify this paragraph as follows:**

***"All mud, silt and foreign matter left after the Owner drains the tank shall be removed from the tank bottom and disposed by the Contractor and not washed through the tank drain. The tank drain shall be properly covered to prevent debris from entering. Sediment must be pumped out of the tank and captured in a sediment bag or removed/collected by other suitable means for disposal off-site. The Owner will have an area for onsite disposal of the collected materials at the Landrum Tank and will be able to accommodate offsite disposal from the Firestone Tank at one of the nearby treatment plants. Offsite disposal of sediment and debris shall comply with all local, state and federal regulations. The Contractor will be responsible for transportation of the sediment."***