ADDENDUM NO. 1
TO
CONTRACT, BONDS AND SPECIFICATIONS
WILLIAMS STREET ELEVATED WATER TANK REHABILITATION
FOR
THE COMMISSION OF PUBLIC WORKS
OF
THE CITY OF LAURENS, SOUTH CAROLINA

Bids Received until 2:00 PM, Local Time, February 11, 2021

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY INSERTING ITS NUMBER IN THE PROPOSAL; FAILURE TO DO SO MAY SUBJECT BONA FIDE BIDDER TO DISQUALIFICATION. THIS ADDENDUM FORMS A PART OF THE PROJECT DOCUMENTS; IT MODIFIES THEM AS FOLLOWS:

TECHNICAL SPECIFICATIONS

SECTION 00 43 41 **BID BOND** **Page 3 OF 3**	**Modify** the Notary Public information **as** follows: *Notary Public* ***~~State of South Carolina-at-Large~~*** ***State of _____-at-Large***
SECTION 09 97 14 **EXISTING TANK PAINTING** **Paragraph 1.11** **Page 7 OF 23**	**Add** the following paragraph **to** the end of this section of the Specifications: ***J. The existing primary power line running along the north property line will be relocated by the Owner but the secondary power feeding the ground facilities onsite will remain.***

QUESTIONS AND ANSWERS

In response to questions that have been formally submitted by bidders, responses are provided as follows and form a part of the Contract Documents:

QUESTIONS FROM BIDDERS

WILLIAMS STREET ELEVATED WATER TANK REHABILITATION
FOR
LAURENS COMMISSION OF PUBLIC WORKS
LAURENS, SOUTH CAROLINA

W&S Project No. 049-20-180 — Bid Date: THURSDAY FEBRUARY 11, 2021 @ 2:00 PM

Update: 2/8/2021 8:59

Question #	Question	Answer
1	Is there an engineers estimate or approximate value for the project?	Approximate cost is $400,000 to $450,000.
2	I understand the attached wording on the umbrella section to be able to meet the underlying 5 mill limits of the General Liability and Auto Liability and not in addition to the 5 mill Aggregate limit required on the underlying coverages. Please verify that this is an accurate assumption.	The umbrella policy is/can be used to meet the 5 mill limits of the General Liability and Auto Liability and is not in addition to the 5 mill Aggregate limit required on the underlying coverages.
3	We are working on the bid bond for this project. Can you please tell me if it is required to be notarized by a South Carolina representative or can it be an out-of-state notary?	An out-of-state notary will be fine. This will be addressed by addenda.
4	General Contractors have reached out to us about substituting a product out in their bid for our product. What is the process for this?	Please refer to Section 01 60 60 in the Specifications. The request for a proposed substitution shall be submitted by the Contractor in the shop drawing submission.
5	Can we get a list of plan holders?	We keep an updated plan holders list on our website (www.wiedeman.com) under Contractor Information.
6	There appears to be power lines running parallel to the fence on the north side of the property that will present a potential safety hazard due to proximity to the containment shroud. Are these lines high voltage?	The existing primary power line running along the north property line will be relocated by the Owner but the secondary power feeding the ground facilities onsite will remain.

NOTES:	1. Company Names and Trade Names have been removed from the questions. The answers contain trade names only to refer to existing installations. These inclusions do not represent an endorsement of the product or the company.
	2. Questions from sales representatives have been edited where appropriate for brevity.
	3. Questions from General Contractors have been left untouched.
	4. Significant Changes in answers previously posted are marked in red.