### **ADDENDUM NO. 1**

ТО

## CONTRACT, BONDS AND TECHNICAL SPECIFICATIONS 2023 WATER STORAGE TANK MAINTENANCE IMPROVEMENTS FOR

# THE COMMISSION OF PUBLIC WORKS SPARTANBURG WATER CITY OF SPARTANBURG, SOUTH CAROLINA

Bids Received until 2:00 PM, Local Time, September 12, 2023

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY INSERTING ITS NUMBER IN THE PROPOSAL; FAILURE TO DO SO MAY SUBJECT BONA FIDE BIDDER TO DISQUALIFICATION. THIS ADDENDUM FORMS A PART OF THE PROJECT DOCUMENTS; IT MODIFIES THEM AS FOLLOWS:


## **TECHNICAL SPECIFICATIONS**

Table of Contents Appendix	Add the following text to the end of this Section of the Specification			
Page 2	Appendix O – New Cut Tank Detail Sheet			
	Appendix P – Boiling Springs Elevated Tank Detail Sheet			
Appendix	Add the following to the Appendix of the Specifications:			
	Appendix O – New Cut Tank Detail Sheet			
	Appendix P – Boiling Springs Elevated Tank Detail Sheet			

# **QUESTIONS AND ANSWERS**

In response to questions that have been formally submitted by bidders, responses are provided as follows and form a part of the Contract Documents.

# **NEW CUT TANK DETAIL SHEET**



B.M. T-11 EL. 926.57

1'-0"-

ROAD

16" D.I.E.L.(S.J.)(71)


CUT

SCALE: 1"=20-0"

SCAL	E.7	_# ,1	~II

CAPACITY CHART									
ATER LINE HT	GALLONS	WATER LINE HT.	GALLONS	WATER LINE HT.	GALLONS	WATER LINE HT.	GALLONS	WATER LINE HT.	GALLONS
1.00'	9058.05	7.00'	83017.12	13.00'	170448.90	19.00'	258570.90	25.00'	345207.40
2.00'	19359.31	8.00'	97259.75	14.00'	185135.90	20.00'	273257.90	26.00'	358640.10
3.00'	30675.31	9.00'	111750,10	15,00'	199822,90	21.00'	287944.90	27.00'	371498_70
4.00'	42834.13	10.00'	126388.00	16.00'	214509.90	22.00'	302582.70	28.00'	383657.60
5.00'	55692.84	11.00'	141074.90	17.00'	229196.90	23.00'	317073.10	29.00'	394973.60
6.00'	69125.50	12.00'	155761.90	18.00'	243883.90	24.00'	331315.70	30.00'	405274.80

# NEW CUT TANK (400,000 GALLONS) CONSTRUCTED 1975 BY UNIVERSAL TANK & IRON WORKS



SPARTANBURG WATER WORKS

# **QUESTIONS FROM BIDDERS**

# 2023 WATER STORAGE TANK MAINTENANCE IMPROVEMETNS FOR

# SPARTANBURG WATER SPARTANBURG, SOUTH CAROLINA

Update:

**W&S Project No. 059-22-180** 

Bid Date: THURSDAY SEPTEMBER 12, 2023 @ 2:00 PM 8/31/2023 8:24

Question #	Question Question	Answer			
	Is there a cost estimate or budget?	The Engineer's Estimate is \$800,000.			
	Is there a Pre-Bid meeting? Is it Mandatory?	There is no pre-bid meeting.			
3	Are the dimensions of the tanks available specifically Height and Diameters?	Addenda 1 will be issued and includes two details sheets for the New Cut Road Tank and the Boiling Springs Elevated Tank.			
	1. Company Names and Trade Names have been removed from the questions. The answers contain endorsement of the product or the company.	trade names only to refer to existing installations. These inclusions do not represent an			
NOTES:	Questions from sales representatives have been edited where appropriate for brevity.				
	3. Questions from General Contractors have been left untouched.				
	4. Significant Changes in answers previously posted are marked in red.				