

---

**ADDENDUM NO. 1**  
**TO**  
**REQUEST FOR BIDS**  
**FOR**  
**REGIONAL WATER TRANSMISSION RIVERSIDE ROAD PROJECT**  
**SUPPLY AND DELIVERY OF 24-INCH AND 16-INCH GATE VALVES**  
**FOR**  
**LANCASTER COUNTY WATER & SEWER DISTRICT**

---

Bids Received until 2:00 PM, Local Time, September 12, 2024

---

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY INSERTING ITS NUMBER IN THE BID SHEET; FAILURE TO DO SO MAY SUBJECT BONA FIDE BIDDER TO DISQUALIFICATION. THIS ADDENDUM FORMS A PART OF THE PROJECT DOCUMENTS; IT MODIFIES THEM AS FOLLOWS:**

**QUESTIONS AND ANSWERS**

In response to questions that have been formally submitted by bidders, responses are provided as follows and form a part of the Contract Documents:

## QUESTIONS FROM BIDDERS

Regional Water Transmission Riverside Road Project - Supply and Delivery of 24-Inch and 16-Inch Diameter Gate Valves  
For  
Lancaster Water and Sewer District

**W&S Project No. 275-22-140**

**Bid Date: THURSDAY SEPTEMBER 12, 2024 @ 2:00 PM**

Update:

9/9/2024 13:59

<i>Question #</i>	<i>Question</i>	<i>Answer</i>
1	Confirm no substitutions or "equals" allowed for the gate valve manufacturers	Substitutions are allowed. Refer to 2.1.J of Specification 40 05 61 and Paragraph 1.7 of the Instructions to Bidders.
2	Confirm Gate valves, all sizes, require Spur Gearing.	A spur gear should be provided for the 16" and 24" valves, if the valves fall within the size gate valve that gearing is recommended by the valve manufacturer.
3	Clarify any domestic, AIS, BABA requirements	AIS and BABA do not apply. However, refer to 1.5.E. of Specification 40 05 61 regarding domestic requirements.
<b>NOTES:</b>	1. Company Names and Trade Names have been removed from the questions. The answers contain trade names only to refer to existing installations. These inclusions do not represent an endorsement of the product or the company. 2. Questions from sales representatives have been edited where appropriate for brevity. 3. Questions from General Contractors have been left untouched. 4. Significant Changes in answers previously posted are marked in red.	